

**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION  
CERTIFICATE.**

No. 65

Date: 08/05/2025

It is certified that an inspection team headed by Dr. A.K. Srivastava  
 (Name of Officers  
 with designation) from Senior Medical Health Officer N.N. Roorkee  
 Department/Office) inspected the Delhi Public School  
Roorkee opp Power Grid D.Dun Road Roorkee (Name & Address of  
 the School) on 08/05/2025 and found that the Delhi Public School  
Roorkee (Name of school) has safe  
 drinking water facilities for the students and members of staff of the institution and is maintaining  
 the hygienic sanitation condition in the school building & the campus as per the norms  
 prescribed by the Central/State/U.T Govt.

The above valid for a period of one year

Signature with Seal: [Signature]  
08/05/2025  
 Name: Dr. A.K. Srivastava  
 Designation: Senior Medical Health Officer N.N. Roorkee

To  
Delhi Public School  
Roorkee  
opp Powergrid D.Dun Road Roorkee  
 (Name & Address of the Institution)

[Signature]  
 PRINCIPAL  
 DELHI PUBLIC SCHOOL  
 ROORKEE



# SCIENTIFIC TESTING LAB

## TEST REPORT

290-291, Near Delhi Public School, Puhana, Roorkee, Haridwar (U.K.) INDIA - 247667

Contact :- +91-9557274448, E. mail- scientifictestinglab@gmail.com

Govt. Approved Test House

LICENSE NO. : 1/UA/CTL/2020

Sample Name	Drinking Water	Report No.	STLR-240425022	
Mfd. By	NS	Reference Date	24/04/2025	
Supplied By	NS	Mfg. Licence No	NS	
Submitted By	Delhi Public School	Receipt Date	24/04/2025	
Address	Village Puhana, Roorkee			
Batch No.	Mfg. Date	Exp. Date	Batch Size	Sample Qty.
NS	NS	NS	NS	1000 ml

### RESULTS OF ANALYSIS

Testing Start Date : 24/04/2025

Reference to protocol	IS:10500:2012		
Description	Clear colourless liquid		
Testing Parameters	Observation	Specification	
Odour	Agreeable	--	
Taste	Agreeable	--	
Colour	1.0	--	
pH	7.36	6.5 to 8.5	
Turbidity	Less than 1	NMT- 1.0	
Total dissolve solid	177 ppm	NMT- 500 ppm	
Calcium (as Ca)	4.29 mg/ltr	NMT- 75 mg/ltr	
Chloride (as Cl)	31.65 mg/ltr	NMT- 250 mg/ltr	
Magnesium (as Mg)	9.13 mg/ltr	NMT- 30 mg/ltr	
Sulphate (as SO <sub>4</sub> )	35.40 mg/ltr	NMT- 200 mg/ltr	
Total Alkalinity (as CaCO <sub>3</sub> )	6.29 mg/ltr	NMT- 200 mg/ltr	
Total Hardness	134.81 mg/ltr	NMT- 200 mg/ltr	
Microbial Contamination	Observation	Specification	
E.Coli	Absent in 100 ml	Should be absent/100 ml	
Total Coliform	Absent in 100 ml	Should be absent/100 ml	

--END OF REPORT--

Note- Party has asked for above test only.

The sample referred to above is of standard quality with respect to above test as per IS:10500:2012.

29/04/2025

Issue Date : 29/04/2025

DATE OF COMPLETION

PERSON IN-CHARGE

SANDEEP TYAGI

(General Manager)  
Authorised Signatory

#### NOTE

1. Sample (s) not drawn by us unless otherwise stated.
2. Total liability of our analytical division is limited to the invoiced amount.
3. Sample will be destroyed after one month from the date of issue of test certificate unless otherwise specified.
4. Test certificate in full or parts shall not be used for promotional or publicity purposes.
5. Results given in report are related to sample tested.

PRINCIPAL  
DELHI PUBLIC SCHOOL  
ROORKEE